

Addendum No.2 (RFI Response)

| | | | |
|-----------------------|---|------------------------|-------------------|
| Project | Bucks County Library, Doylestown TR Improvements | Response Author | Stephen G. Custer |
| RHJ Project ID | 2018-0131 | Response Date | 09/27/2018 |
| RFI ID | Addendum No.2 | | |
| Submitted By | Kristi Engler | | |
| Received On | 09/26/2018 | | |

Question 1:

Please provide the name of the fire alarm vendor for the building.

Answer 1:

The owner's fire alarm vendor is Fortress Protection, LLC-856-424-3000 or 215-854-8400.

Question 2:

Are there existing closers on opening E1? If so do the existing closers open 180 degrees. Also, on the pair of doors E2, do you want a mag lock on both leaves, or on just one with the other having flush bolts?

Answer 2:

Type E1 doors have existing closers that limit the door swing to ± 120 degrees. Modify or replace closers as needed to allow doors to open 180 degrees.

Type E2 doors should have a mag lock on both door leaves. Provide either a dual-contact mag lock or two individual mag locks (one contact per door).

End of Response