

Addendum 02

Project	Bucks County Free Library Doylestown Branch IT & Server Room
RHJ Project ID	2025-0597
Addendum No.	02
Submitted By	Bucks County Free Library
Issued	2026-09-25

TO ALL BIDDERS:

This addendum shall modify the Contract Drawings and Specifications as herein noted and delineated. The Contractor shall so note the changes and modify the bid proposal accordingly. This addendum shall, in total, be added to the Contract Documents for the above referenced project.

Item #1 RFI Question:

- ***Dwg E.3 - New work Power & Signal Note #3 - Please provide drawing that shows location of the fire pump controller, conduit size requirements, and wire/cable requirements.***

RFI Answer:

The generator does not supply the fire pump. Therefore, control wiring and conduit from the generator to the fire pump controller is not required.

Item #2 RFI Question:

- ***Will work be performed during normal business hours?***

RFI Answer:

Yes.

Item #3 RFI Question:

- ***Please confirm the owner is responsible for permit fees.***

RFI Answer:

No, all associated permit fees shall be included in the contractors final bid proposal.

Item #4 RFI Question:

- ***Is this a single prime bid? Also if so do we still need to include the RCO?.***

RFI Answer:

Yes, it is a single prime bid.

If the bid exceeds \$250,000, the RCO form is required.

York, PA
1601 2nd Avenue
York, PA 17403
(717) 845-3644

Philadelphia, PA
123 S. Broad Street, Suite 1140
Philadelphia, PA 19109
(215) 279-5845

Paoli, PA (HQ)
10 Leopard Road, Floor 2
Paoli, PA 19301
(610) 337-4555

Mount Laurel, NJ
303 Fellowship Road, Suite 212
Mount Laurel, NJ 08054
(856) 252-0040

Wilmington, DE
3316 S. Rockfield Drive
Wilmington, DE 19810
(302) 482-2269